

# DEPURATORE BORGOMANERO ANALISI DI CONTROLLO E CONTROLLI DELEGATI ANNO 2019

Parametro			Azoto totale	BOD5	COD	Fosforo totale	Solidi sospesi totali
U.D.M.			mg/l	mg/l	mg/l	mg/l	mg/l
AUTOCONTROLLO	15/01/2019		15	25	125	2	35
		Ing.	27,0	130,0	257,0	3,53	100,0
		Usc.	14,5	8,0	18,0	0,98	3,0
		% rid.	46,3	93,8	93,0	72,2	97,0
CONTR.DELEGATO	29/01/2019	Ing.	27,2	155,0	238,0	3,51	20,0
		Usc.	15,7	7,0	21,0	1,38	6,0
		% rid.	42,3	95,5	91,2	60,7	70,0
AUTOCONTROLLO	05/02/2019	Ing.	26,7	140,0	230,0	2,74	50,0
		Usc.	11,4	4,0	16,0	0,49	3,0
		% rid.	57,3	97,1	93,0	82,1	94,0
CONTR.DELEGATO	12/02/2019	Ing.	30,4	110,0	186,0	3,97	75,0
		Usc.	15,8	5,0	15,5	0,801	0,0
		% rid.	48,0	95,5	91,7	79,8	100,0
CONTR.DELEGATO	06/03/2019	Ing.	31,1	110,0	232,0	3,14	60,0
		Usc.	14,89	4,0	16,0	0,4	3,0
		% rid.	52,1	96,4	93,1	87,3	95,0
AUTOCONTROLLO	19/03/2019	Ing.	38,2	130,0	289,0	3,63	90,0
		Usc.	15,0	11,0	23,0	1,06	0,0
		% rid.	60,7	91,5	92,0	70,8	100,0
AUTOCONTROLLO	10/04/2019	Ing.	23,3	80,0	186,0	2,51	60,0
		Usc.	12,9	7,0	22,0	0,79	3,0
		% rid.	44,6	91,3	88,2	68,5	95,0
CONTR.DELEGATO	17/04/2019	Ing.	17,1	88,0	157,0	3,95	40,0
		Usc.	11,94	5,0	18,0	0,64	3,0
		% rid.	30,2	94,3	88,5	83,8	92,5
AUTOCONTROLLO	08/05/2019	Ing.	26,1	78,0	169,0	3,4	60,0
		Usc.	10,9	6,0	16,0	0,65	0,0
		% rid.	58,2	92,3	90,5	80,9	100,0
CONTR.DELEGATO	15/05/2019	Ing.	28,1	170,0	319,0	2,17	80
		Usc.	9,38	7,0	19,0	0,7	0,0
		% rid.	66,6	95,9	94,0	67,7	100,0
AUTOCONTROLLO	05/06/2019	Ing.	19,5	350,0	548,0	2,32	40,0
		Usc.	9,89	6,0	19,0	0,72	0,0
		% rid.	49,3	98,3	96,5	69,0	100,0
CONTR.DELEGATO	26/06/2019	Ing.	18,5	50,0	118,0	2,46	40,0
		Usc.	7,57	4,0	16,0	0,51	0,0
		% rid.	59,1	92,0	86,4	79,3	100,0
AUTOCONTROLLO	03/07/2019	Ing.	21,3		139,0	2,62	60,0
		Usc.	10,3		10,0	0,26	3,0
		% rid.	51,6		92,8	90,1	95,0
CONTR.DELEGATO	10/07/2019	Ing.					
		Usc.					
		% rid.					
% rid. MEDIA			51,3	87,2	91,6	76,3	95,3

Sostituisce 12/06 come da nostra  
PEC: AUT/16956 del 10/06 c.a.